



Popeyes Louisiana Kitchen  
 400 Perimeter Center Terrace, Suite 1000  
 Atlanta, GA 30346


## Design & Construction Field Bulletin


Date	June 6, 2016 (Issuance #002)
Field Bulletin No.	FB-006 2016 (2 pages)
Category	Roofing
Subject	Durolast Roofing Specification
Prototype Set Referenced	PLK 15 Series Drawings
Prototype Drawings Referenced	Sheets A4 & A7
D&C Contact	design@popeyes.com

### Comments

The roofing detail on Sheet A4 does not match the specification on Sheet A7. The detail has been revised to note "ROOFING SYSTEM". In addition, roofing specification on Sheet A7 has been revised.

Refer to the sheets for the change.





2

**NOTE:**

ROOFING SYSTEM SHALL BE WHITE PVC  
50-MIL MEMBRANE ROOFING AS  
MANUFACTURED BY:

1) DURO-LAST OR EQUAL

PROVIDE OVERALL THERMAL RESISTANCE FOR  
ROOFING SYSTEM AS FOLLOWS: MINIMUM R-VALUE 30.

1 ROOF PLAN  
A4 1/4"=1'-0"